



NOTES

- (1) Shaded area is considered working space and shall be kept clear of all obstacles (including landscaping) to permit ready and safe operation and maintenance of the service equipment.
- (2) Electric meter shall be protected with extended curbs or ballards (guard posts) in traffic areas to maintain working space.
- (3) Clearance from meter socket, gas regulator, canales (roof drains) is 36" minimum.
- (4) This drawing is to be used for dimensioning purposes only. Canales (roof drains) are NOT allowed to be installed over electric and gas meters.

REFERENCES

- (1) NEC 110-16 Working Space
- (2) See DS-7-16.26 Guard Post