

PNM Preliminary Reliability Analysis

Astrape Consulting

Nick Wintermantel

4/18/2017

Topics

- **Resource Adequacy Overview**
- **SERVM Model Overview**
- **Traditional Reserve Margin Target**
- **Flexibility Metrics**
- **RPS Scenarios and Rules of Thumb**

Resource Adequacy Overview

Resource Adequacy

- **Resource Adequacy Definition: The ability of supply-side and demand-side resources to meet the aggregate electrical demand (NERC Definition)**
- **Resource Adequacy Studies**
 - **Reserve Margin Study**
 - Goal: Calculate generating capacity deficiencies and determine the amount of capacity needed to maintain resource adequacy during peak conditions
 - Purpose: Input or validation of expansion planning processes
 - **Flexibility Study**
 - Goal: Determine reliability deficiencies including both firm load shed events and renewable resource curtailment due to system ramping/startup constraints (not capacity deficiencies)
 - Purpose: Provides assistance in setting appropriate parameters for resource additions and to determine system operating reserve requirements

Resource Adequacy Metrics

- **Loss of Load Expectation ($LOLE_{CAP}$):** Expected number of firm load shed events in a given year due to capacity shortfalls
- **Loss of Load Expectation ($LOLE_{FLEX}$):** Expected number of firm load shed events in a given year due to not having enough ramping capability

- **Loss of Load Hours ($LOLH_{CAP}$):** Expected number of hours of firm load shed in a given year due to capacity shortfalls
- **Loss of Load Hours ($LOLH_{FLEX}$):** Expected number of hours of firm load shed in a given year due to not having enough ramping capability


- **Expected Unserved Energy (EUE_{CAP}):** Expected amount of firm load shed in MWh for a given year due to capacity shortfalls
- **Expected Unserved Energy (EUE_{FLEX}):** Expected amount of firm load shed in MWh for a given year due to not having enough ramping capability

Definitions of Existing and **New** Reliability Metrics

Traditional "Generic Capacity" Metrics

LOLE_{Cap}


Traditional metric to capture events that occur due to capacity shortfalls in peak conditions




New "Flexible Capacity" Metrics

LOLE_{FLEX}

New metric to capture events due to system ramping deficiencies of longer than one hour in duration



New metric to capture events due to system ramping deficiencies inside a single hour



SERVM Model Overview

Strategic Energy Risk Valuation Model (SERVM)

- **SERVM has over 30 years of use and development**
- **Probabilistic hourly and intra-hour chronological production cost model designed specifically for resource adequacy and system flexibility studies**
- **SERVM calculates both resource adequacy metrics and costs**
- **SERVM used in a variety of applications for the following entities:**
 - Southern Company
 - TVA
 - Louisville Gas & Electric
 - Kentucky Utilities
 - Duke Energy
 - Progress Energy
 - FERC
 - NARUC
 - PNM
 - TNB (Malaysia)
 - EPRI
 - Santee Cooper
 - CLECO
 - California Public Utilities Commission
 - Pacific Gas & Electric
 - ERCOT
 - MISO
 - PJM
 - Terna (Italian Transmission Operator)
 - NCEMC
 - Oglethorpe Power

SERVM Uses

- **Resource Adequacy**
 - Loss of Load Expectation Studies
 - Optimal Reserve Margin
 - Operational Intermittent Integration Studies
 - Penetration Studies
 - System Flexibility Studies
 - Effective Load Carrying Capability of Energy Limited Resources
 - Wind/Solar
 - Demand Response
 - Storage
 - Fuel Reliability Studies
 - Gas/Electric Interdependency Questions
 - Fuel Backup/Fixed Gas Transportation Questions
 - Transmission Interface Studies
- **Resource Planning Studies**
 - Market Price Forecasts
 - Energy Margins for Any Resource
 - System Production Cost Studies
 - Evaluate Environmental/Retirement Decisions
 - Evaluate Expansion Plans


Resource Commitment and Dispatch

- **8760 Hourly Chronological Commitment and Dispatch Model**
- **Simulates 1 year in approximately 1 minute allowing for thousands of scenarios to be simulated which vary weather, load, unit performance, and fuel price**
- **Capability to dispatch to 1 minute interval**
- **Respects all unit constraints**
 - Capacity maximums and minimums
 - Heat rates
 - Startup times and costs
 - Variable O&M
 - Emissions
 - Minimum up times, minimum down times
 - Must run designations
 - Ramp rates
- **Simulations are split across multiple processors linked up to the SQL Server**

Resource Commitment and Dispatch

- **Commitment Decisions on the Following Time Intervals allowing for recourse**
 - Week Ahead
 - Day Ahead
 - 4 Hour Ahead, 3 Hour Ahead, 2 Hour Ahead, 1 Hour Ahead, and Intra-Hour
- **Load, Wind, and Solar Uncertainties at each time interval (decreasing as the prompt hour approaches)**
- **Benchmarked against other production models**

1 - 4 Hour Ahead Forecast Error



Current Position: t = 0

Ancillary Service Modeling

- **Ancillary Services Captured**
 - Regulation Up Reserves
 - Regulation Down Reserves
 - Spinning Reserves
 - Non Spinning Reserves
 - Load Following Reserves
- **Co-Optimization of Energy and Ancillary Services**
 - Each committed resource is designated as serving energy or energy plus one of the ancillary services for each period

SERVM Framework

- **Base Case Study Years (2021 and 2024)**


- Weather (36 years of weather history)
 - Impact on Load
 - Impact on Intermittent Resources
- Economic Load Forecast Error (distribution of 5 points)
- Unit Outage Modeling (thousands of iterations)
 - Multi-State Monte Carlo
 - Frequency and Duration

- Base Case Total Scenario Breakdown: 36 weather years x 7 LFE points = 252 scenarios
- Base Case Total Iteration Breakdown: 252 scenarios * 10 unit outage iterations = 2,520 iterations
- Intra Hour Simulations at 5-minute Intervals

Reserve Margin Study

Load Modeling: Summer Peak Weather Uncertainty

Includes Entire Balancing Area




Economic Load Forecast Error

Using CBO GDP approach and assuming 30% multiplier for electric load growth compared to GDP growth


Load Forecast Error Multipliers	Probability %
0.95	2.7%
0.97	14%
0.99	23.8%
1.00	19.1%
1.01	23.8%
1.03	14%
1.05	2.7%

Renewable Shapes: 36 Years



- Wind Shapes Based on Historical Data
- New Wind given 40+% Capacity Factor

- Solar Shapes Based on NREL Data
- Represented by 6 Locations Across the State
- Both Fixed and Tracking




Unit Outage Modeling

- **Full Outages**
 - Time to Repair
 - Time to Failure
- **Partial Outages**
 - Time to Repair
 - Time to Failure
 - Derate Percentage
- **Startup Failures**
- **Maintenance Outages**
- **Planned Outages**
- **Based on Historical Operation**


Unit Name	Capacity (MW)	EFOR
P. VERDE_1	134	2.15
P. VERDE_2	134	0.73
P. VERDE_3	134	3.11
FOURCORN_4	100	20.75
FOURCORN_5	100	17.61
SAN JUAN_1	170	18.29
SAN JUAN_4	327	16.06
LUNA_1	185	5.42
AFTONCC_1	230	5.77
DELTA_1	138	9.32
La_Luz	40	6.64
REEVES_1	44	5.05
REEVES_2	44	0.71
REEVES_3	66	7.17
VLNCPA_1	145	1.43
LORDSBRG_1	40	7.08
LORDSBRG_2	40	6.45

System Unplanned Outages



Study Topology and Market Assistance

2013 Reserve Margin Study



Emergency Operating Procedures


- Demand Response

	Power Saver Program	Peak Saver Program
Capacity (MW)	33.75	20
Season	June-Sept	June-Sept
Hours Per Year	100	100
Hours Per Day	4	6

- Firm load shed to maintain reserves equal to 4% of load

LOLE_{CAP} Results

2021 Study Year



Month	LOLE _{Cap}
1	0%
2	0%
3	0%
4	0%
5	0%
6	22%
7	45%
8	32%
9	1%
10	0%
11	0%
12	0%

- Recommend minimum reserve margin at no higher than 0.2 LOLE_{CAP}: 17% reserve margin
- Traditional 1 day in 10 year standard: 0.1 LOLE_{CAP} = 21% reserve margin
- Assuming no external regions, a 16.5% reserve margin results in over 8 LOLE_{CAP} events per year. Neighbor assistance during peak hours can range from 0 MW to 300 MW depending on neighbor conditions.


Flexibility Metrics

Definitions of Existing and **New** Reliability Metrics

Traditional "Generic Capacity" Metrics

LOLE_{Cap}


Traditional metric to capture events that occur due to capacity shortfalls in peak conditions




New "Flexible Capacity" Metrics

LOLE_{FLEX}


New metric to capture events due to system ramping deficiencies of longer than one hour in duration



New metric to capture events due to system ramping deficiencies inside a single hour



Renewable Curtailment Example



Represents a day in the 2021 50% RPS scenario

Flexibility Study Approach


- **Identify $LOLE_{FLEX}$ events and renewable curtailment (overgen) events**
- **Solve the deficiencies using the following approaches and calculate costs:**
 - Change operating procedures (i.e. raise load following requirement)
 - Add flexible capacity and/or replace existing capacity
- **Production Costs = Fuel Costs + Variable O&M + Emission Costs + Cost of EUE**
 - PPA prices assumed for wind and solar

Base Case Physical Reliability Results

Varying Operating Reserve Levels

- Study Years: 2021
- Reg Requirement: 4% of Load
- Spin + Load Following Requirement = Simulated at 5% and 7%
- Quick Start Target: 4% of Load

System reliability is reasonable with 7% LF target



	Renewable Penetration	LF Target	Renewable Curtailment	Renewable Curtailment	LOLE CAP	LOLE FLEX	Production Costs
	% of Load	% of Load	% of Renewable	MWh	Events Per Year	Events Per Year	M\$
2021 Base Case	17.0%	5.0%	1.8%	43,131	0.18	0.18	369.9
2021 Base Case	17.0%	7.0%	1.9%	45,019	0.18	0.08	373.3

Cost Increase due to LF increase

Curtailment Comparison 1x20 MW solar plant = annual output of 44,000 MWh

Base Case Physical Reliability Results

Varying Operating Reserve Levels

- Study Year: 2024
- Reg Requirement: 4% of Load
- Spin + Load Following Requirement = Simulated at 5% and 7%
- Quick Start Target: 4% of Load

System reliability is reasonable with 7% LF target



	Renewable Penetration	LF Target	Renewable Curtailment	Renewable Curtailment	LOLE CAP	LOLE FLEX	Production Costs
	% of Load	% of Load	% of Renewable	MWh	Events Per Year	Events Per Year	M\$
2024 Base Case	21.1%	5.0%	1.1%	34,213	0.19	0.44	514.2
2024 Base Case	21.1%	7.0%	1.1%	34,747	0.19	0.11	519.6

Cost Increase due to LF increase

Curtailment Comparison 1x20 MW solar plant = annual output of 44,000 MWh

2024 Base Case (Monthly Basis)

2024	LOLE Cap	LOLE Flex	Curtailment
Month	Events Per Year	Events Per Year	MWh
1	-	0.007	2,667
2	-	0.008	3,455
3	-	0.026	3,718
4	-	0.016	3,413
5	-	0.007	4,747
6	0.036	0.002	1,918
7	0.090	0.009	931
8	0.064	0.007	1,001
9	0.003	0.000	1,920
10	-	0.016	2,440
11	-	0.011	4,494
12	-	0.005	3,044
Total	0.193	0.114	33,747


RPS Scenarios and Rules of Thumb

2024 RPS Scenarios

Technology	LF Target
Base Case	5%, 7%
Base Case 40% RPS (66.7% Solar)	7%, 13%, 15%
Base Case 40% RPS (66.7% Wind)	7%, 13%, 15%
Base Case 50% RPS (66.7% Solar)	7%, 13%, 15%
Base Case 50% RPS (66.7% Wind)	7%, 13%, 15%
Base Case 80% RPS (66.7% Solar)	7%, 13%, 15%
Base Case 80% RPS (66.7% Wind)	7%, 13%, 15%

To build RPS portfolios, additional solar and wind was added to the system: Either 66% of the incremental additions were designated as wind or solar

Net Load Intra Hour Uncertainty




2024 RPS Scenarios @ 7% LF

	Renewable Penetration	LF Target	Curtailment	Curtailment	LOLE _{FLEX}	Production Costs
	% of Load	% of Load	% of Renewable	MWh	Events Per Year	M\$
Base Case	21.1%	7.0%	1.1%	33,747	0.11	519.6
Base Case 40% RPS (66.7% Solar)	40.9%	7.0%	10.5%	613,496	6.83	527.5
Base Case 40% RPS (66.7% Wind)	40.6%	7.0%	7.8%	454,097	5.04	523.5
Base Case 50% RPS (66.7% Solar)	51.4%	7.0%	18.2%	1,333,517	16.05	553.8
Base Case 50% RPS (66.7% Wind)	50.8%	7.0%	13.1%	948,907	16.39	541.4
Base Case 80% RPS (66.7% Solar)	82.8%	7.0%	37.7%	4,457,962	55.62	686.2
Base Case 80% RPS (66.7% Wind)	81.7%	7.0%	29.4%	3,423,730	68.60	650.3

Curtailment Comparison 1x20 MW solar plant = annual output of 44,000 MWh
 1x500 MW solar plant = annual output of 1,100,000 MWh


2024 RPS Scenarios @ 7% LF



2024 RPS Scenarios @ 15% LF

	Renewable Penetration	LF Target	Renewable Curtailment	Renewable Curtailment	LOLE _{FLEX}	Production Costs
	% of Load	% of Load	% of Renewable	MWh	Events Per Year	M\$
Base Case	21.1%	7.0%	1.1%	33,747	0.11	519.6
Base Case 40% RPS (66.7% Solar)	40.9%	15.0%	12.9%	751,179	0.44	554.0
Base Case 40% RPS (66.7% Wind)	40.6%	15.0%	10.0%	579,932	0.28	549.7
Base Case 50% RPS (66.7% Solar)	51.4%	15.0%	19.8%	1,450,165	1.22	575.1
Base Case 50% RPS (66.7% Wind)	50.8%	15.0%	15.3%	1,111,892	0.85	564.2
Base Case 80% RPS (66.7% Solar)	82.8%	15.0%	38.8%	4,578,472	7.12	694.7
Base Case 80% RPS (66.7% Wind)	81.7%	15.0%	31.0%	3,610,875	10.15	656.2


Renewable Curtailment



Average = % of total renewable fleet curtailed at each RPS level

Marginal = % of next MWh that will be curtailed at each RPS level

Cost by RPS Level



Assumes \$39 PPA pricing for new solar and \$40 PPA pricing for new wind.

2024 RPS Scenarios add Flexible Generation or Battery

	Renewable Penetration	LF Target	Curtailement	Curtailement	LOLE _{CAP}	LOLE _{FLEX}	Production Costs
	% of Load	% of Load	%	MWh	Events Per Year	Events Per Year	M\$
Base Case 40% RPS (66.7% Wind)	40.6%	13%	9.4%	541,689	0.10	0.48	543.0
Base Case 40% RPS (66.7% Wind)	40.6%	15%	10.0%	579,932	0.10	0.28	549.7
Base Case 40% RPS (66.7% Wind) and 2 LM6000 (80 MW)	40.6%	13%	9.2%	534,093	0.04	0.50	539.0
Base Case 40% RPS (66.7% Wind) and 100 MW 2 hour storage	40.6%	13%	8.9%	514,306	0.04	0.31	536.7
Base Case 40% RPS (66.7% Wind) and 100 MW 4 hour storage	40.6%	13%	8.6%	495,383	0.03	0.27	535.7
Base Case 40% RPS (66.7% Wind) and 100 MW 6 hour storage	40.6%	13%	8.4%	483,445	0.02	0.27	535.5

Represents First Pass at Results; Production Costs do not include capital costs

Load Following Requirements

General Takeaways

RPS	Required Load Following	Renewable Curtailment
20%	7% of Load	<50,000 MWh
30%	13% of Load	100,000 - 200,000 MWh
40%	>15% of Load	400,000 - 800,000 MWh
50%	>15% of Load + Significant Additional Flexible Resources	900,000 - 1,500,000 MWh
80%	>15% of Load + Significant Additional Flexible Resources	3,500,000 - 4,500,000 MWh